

Permit No. PPC/A/1022412 Dargavel EfW facility  
Scotgen (Dumfries) Ltd

**Incident Report     Stream 1**

Incident notified by phone Y/N  
Confirmed by 1st class post/Fax Y/N  
Report complete here Y/N

Y
Y
Y

**Nature of the incident**

SCC temperature (1098C)  
Oxygen  
CO breach 10 min and 30 min however likely compliant  
VOC 30 min breach

**Time and duration of the incident**

06/09/10 17:22-29 & 17:48-54 for oxygen  
06/09/10 17:29-30 & 17:36-37 for temperature

**Receiving environmental medium or media**

None

**Estimate of quantity and composition**

Detailed by supplied tables

**Measures taken to prevent or minimise emission**

Abatement controls, oxygen control and temperature control,

**Report of the Investigation**

Refer to attached documentation  
Build up of energy within system which rapidly burned off, decreasing oxygen which caused fans to increase suddenly decreasing temperature as result.

**Steps taken to bring the incident to an end**

automatic control to reduce air flow

**Proposals for remediation**

encourage slow release of energy to the system

**Proposals for preventing a repetition**

encourage slow release of energy to the system

**END**

Disclaimer: I hope all the information supplied is suitable if you could please get in touch within 14 working days if requiring further information