

Ash Analysis Data : Dargavel Facility

Parameter	Method	LOD	Units	03/11/2009	09/11/2009	25/11/2009	17/12/2009	12/03/2010	25/03/2010	22/03/2010	30/03/2010	26/04/2010	10/05/2010	25/05/2010
Loss on Ignition	gravimetric	0.1	% wt/wt	0.38	0.34	<0.1	0.14	0.12	<0.1	0.34	0.64	0.28	0.78	1.27
Ash	Gravimetric	0.1	% wt/wt	99.6	99.7	99.9	99.9	99.9	>99.9	99.7	99.4	99.7	99.2	98.7
Moisture Content	gravimetric	0.1	% wt/wt	<0.1	0.13	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Bicarbonate (as NaHCO <sub>3</sub> )	volumetric	0.1	% wt/wt	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Carbonate ( as Na <sub>2</sub> CO <sub>3</sub> )	volumetric	0.1	% wt/wt	0.3	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1

Note:  
All analysis, except Moisture content, carried out on dried material.